



NOTES:

SEWER SERVICE, PVC SCHEDULE 40 4" OR 6" AS SPECIFIED

2% MINIMUM SLOPE OR 12% MAXIMUM SLOPE, 1/4" PER FOOT

ALL PIPE SHALL BEDDED IN GRANULAR BORROW 3149 B.1 OR COURSE FILTER AGGREGATE 3149H

END OF SERVICE SHALL BE 7' TO 9' DEEP AT END OF SERVICE. THE END SHALL BE A FACTORY JOINT WITH PLUG, USING A FACTORY MANUFACTURED ADAPTOR WHERE NECESSARY



SANITARY SEWER SERVICE

STANDARD
PLATE #
SS-1

LAST REVISION
NOVEMBER 2014

CITY OF MAPLE GROVE ENGINEERING
& PUBLIC WORKS DEPARTMENTS