



NOTES:

HYDRANT SHALL BE WATEROUS PACER MODEL WB67-250 OR APPROVED EQUIVALENT.

HYDRANT SHOULD HAVE TWO (2)-4 INCH AND ONE-HALF (4 1/2") PUMPER CONNECTIONS WITH WATEROUS THREADS AS FOLLOWS: 4-1/2" THREADS, 5 9/16" O.D. BY 4 THREADS PER INCH AND A 16" BREAK OFF.

ALL HYDRANTS AND GATE VALVES SHALL HAVE MECHANICAL JOINT CONNECTIONS.

ALL VALVES TO OPEN COUNTER-CLOCKWISE.

ALL BACKFILL SHALL BE PROPERLY COMPACTED.

FIRE HYDRANTS SHALL BE PAINTED RED AT THE FACTORY.

WEEP HOLE TO REMAIN OPEN.



LAST REVISION
JANUARY 2021

HYDRANT AND GATE VALVE INSTALLATION

CITY OF MAPLE GROVE ENGINEERING
& PUBLIC WORKS DEPARTMENTS

STANDARD
PLATE #
WM-4