



NOTES:

ANY CURB STOP LOCATED IN BLACKTOP OR CONCRETE DRIVEWAY OR SIDEWALK SHALL BE COVERED WITH A 10" G.V. BOX TOP SECTION.

ALL WATER SERVICES SHALL BE 1" PE-4710 BLUE WITH CLEAR CORE SIDR-7 PIPE.

ALL NEW WATER SERVICES INSTALLED SHALL USE A SMITH-BLAIR 372 STAINLESS STEEL SADDLE.

CORPORATION SHALL BE A 1" FORD FB 1001-4-NL, MCDONALD 74701-B-33, OR OWNER APPROVED ALTERNATE.

CURB STOP AND BOX SHALL BE 1" FORD B22-444-M-NL WITH C06-44-NL PACK JOINT COUPLING, MCDONALD 76104 WITH 74755-33 NL SERVICE FITTING, OR OWNER APPROVED ALTERNATE WITH A STATIONARY ROD AND BE ABLE TO ADJUST FROM 84" TO 96".

STIFFENERS REQUIRED ON ALL FLEXIBLE PLASTIC CONNECTIONS.

WATER SERVICE MUST BE CONTINUOUS WITH NO JOINTS.

SANITARY AND WATER SERVICE LINES SHALL BE INSTALLED IN THE SAME TRENCH WITH 3 FEET OF SEPARATION, WATER SERVICE ON UPSTREAM SIDE OF SANITARY SERVICE.

CURB BOXES INSTALLED IN AREAS WHERE THE BOULEVARD IS TO BE CUT AT A LATER DATE, TOP OF CURB BOX SHALL BE SAME ELEVATION AS TOP OF CURB.



LAST REVISION
JANUARY 2021

**1" WATER SERVICE WITH PVC
WATERMAIN**

CITY OF MAPLE GROVE ENGINEERING
& PUBLIC WORKS DEPARTMENTS

STANDARD
PLATE #
WM-7