



**NOTES:**

PIPE SHALL BE CENTERED UNDER INSULATION UNLESS OTHERWISE SPECIFIED

| <u>COVER OVER PIPE - "A"</u> | <u>WIDTH OF INSULATION BOARD - "B"</u> |
|------------------------------|--|
| 2'                           | 12'                                    |
| 3'                           | 10'                                    |
| 4'                           | 8'                                     |
| 5'                           | 6'                                     |
| 6'                           | 4'                                     |

2" OF INSULATION = 2' OF COVER